



Grease Interceptor Certification

Every food service establishment in the City of Mt. Juliet sewage service area must have their grease interceptor inspected annually to verify that all components of the grease control equipment are present and in good working condition. Furthermore, the inspection will identify any structural problems with the grease interceptor.

Facility Name: _____ Phone # _____

Address: _____ City: _____, TN. Zip Code: _____

1. Interceptor completely emptied and cleaned before inspection? Yes _____ No _____ *
2. There is access to all interceptor chambers for cleaning and inspections? Yes _____ No _____ *
3. Influent (inlet) T is attached and extends downwards at least 2/3 depth of tank? Yes _____ No _____ *
4. Effluent (outlet) T is attached and extends downwards to within 12" of tank bottom? Yes _____ No _____ *
5. Effluent (outlet) T is made of non-collapsible material that does not easily flex or bend (i.e. minimum schedule 40 PVC, etc.), and is secure? Yes _____ No _____ *
6. Interceptor tank has visible holes or leaks? Yes _____ * No _____
7. Mid-wall baffle(s) is secure and operational? Yes _____ No _____ *
8. Interceptor maintaining structural integrity? Yes _____ No _____ *
9. Sewer clean out covers missing or damaged? Yes _____ * No _____

***If the answer to any of the above questions has " * " beside the response, then a statement of the plan of action taken (or plans for action to be taken) need to be provided below (attach additional sheets if necessary):**

Inspector Certification

I _____ of _____
(Print Name) (Print company)

certify that the above listed facility has an approximate _____ gallon capacity grease interceptor. I have examined the interceptor and found it to be in good working condition and functioning properly.

(Signature) (Date) (Phone number)

Facility Owner/Manager Certification

I _____ certify to the best of my knowledge the above statements to be true and correct.
(Print Name)

(Signature) (Date)

Submit Certification Form to:

City of Mt. Juliet
FOG Control Program
71 East Hill Street
Mt. Juliet, Tenn. 37122